

BDD Finished Drinking Water			February 19, 2013			February 27, 2013			June 11, 2013			December 2, 2013						
Parameter	MCL	Units	Result	Qualifier	MRL	Result	Qualifier	Uncertainty	MDL	MRL	PQL	Result	Qualifier	Uncertainty	MDL	MRL	PQL	
<b>Primary Contaminants</b>																		
<b>Microorganisms</b>																		
Total Coliforms	5.0 %	present/absent				absent			0.0000000000	0.0000000000		absent			0.0000000000	0.0000000000		0.0000000000
E. Coli		present/absent				absent			0.0000000000	0.0000000000		absent			0.0000000000	0.0000000000		0.0000000000
<b>Disinfection Byproducts</b>																		
Bromate	0.01	mg/L	<		0.0010000000				0.0010000000	0.0010000000		<		0.0010000000	0.0010000000			0.0010000000
Chlorite	1	mg/L	<		0.0100000000				0.0100000000	0.0100000000		<		0.0100000000	0.0100000000			0.0100000000
<b>Haloacetic Acids</b>																		
Dichloroacetic Acid		mg/L			0.0027700000				0.0010000000	0.0010000000		0.0093000000			0.0010000000	0.0010000000		0.0044600000
Trichloroacetic Acid		mg/L			0.0011900000				0.0010000000	0.0010000000		0.0058900000			0.0010000000	0.0010000000		0.0039200000
Monochloroacetic Acid		mg/L			0.0020000000				0.0020000000	0.0020000000		<		0.0020000000	0.0020000000			0.0020000000
Dibromoacetic Acid		mg/L			0.0015600000				0.0010000000	0.0010000000		<		0.0010000000	0.0010000000			0.0010000000
Monobromoacetic Acid		mg/L			0.0010000000				0.0010000000	0.0010000000		<		0.0010000000	0.0010000000			0.0010000000
Total Haloacetic Acids	0.06	mg/L			0.0052000000				0.0010000000	0.0010000000		0.0152000000			0.0010000000	0.0010000000		0.0094700000
<b>Trihalomethanes</b>																		
Chloroform		mg/L			0.0006050000				0.0006050000	0.0005000000		0.0021000000			0.0005000000	0.0005000000		0.0083100000
Bromoform		mg/L			0.0005440000				0.0005440000	0.0005000000		0.0005000000			0.0005000000	0.0005000000		0.0050000000
Bromodichloromethane		mg/L			0.0036600000				0.0036600000	0.0005000000		0.0083000000			0.0005000000	0.0005000000		0.0050000000
Dibromochloromethane		mg/L			0.0008110000				0.0008110000	0.0005000000		0.0005000000			0.0005000000	0.0005000000		0.0050000000
Total Trihalomethanes	0.08	mg/L			0.0050000000				0.0008110000	0.0005000000		0.0284000000			0.0005000000	0.0005000000		0.0083100000
<b>Disinfectants</b>																		
Chlorine	4	mg/L			0.6340000000				0.0500000000	0.0500000000		0.5190000000			0.0500000000	0.0500000000		0.5590000000
Chloramine	4	mg/L			0.6870000000				0.0500000000	0.0500000000		0.9740000000			0.0500000000	0.0500000000		0.2960000000
Chlorine Dioxide	0.8	mg/L			0.0500000000				0.0500000000	0.0500000000		0.1420000000			0.0500000000	0.0500000000		0.2500000000
<b>Inorganic Chemicals</b>																		
Antimony	0.005	mg/L	<		0.0010000000				0.0002300000	0.0010000000		<		0.0002300000	0.0010000000	0.0010000000		0.0010000000
Arsenic	0.01	mg/L	<		0.0057000000				0.0057000000	0.0010000000		0.0025700000			0.0010000000	0.0010000000		0.0010000000
Barium	2	mg/L	<		0.1000000000				0.0040000000	0.0020000000		0.0630000000			0.0020000000	0.0020000000		0.0400000000
Beryllium	0.004	mg/L	<		0.0005000000				0.0005000000	0.0020000000		0.0000200000			0.0005000000	0.0020000000		0.0020000000
Cadmium	0.005	mg/L	<		0.0004000000				0.0004000000	0.0020000000		0.0001000000			0.0001000000	0.0010000000		0.0020000000
Chromium	0.1	mg/L	<		0.0010000000				0.0010000000	0.0060000000		0.0000210000			0.0060000000	0.0060000000		0.0060000000
Copper	(A.L.) 1.3	mg/L			0.0013000000				0.0013000000	0.0010000000		0.0023000000			0.0010000000	0.0010000000		0.0013000000
Lead	(A.L.) 0.015	mg/L			0.0008000000				0.0008000000	0.0010000000		0.0008000000			0.0008000000	0.0010000000		0.0010000000
Mercury	0.002	mg/L	<		0.0002000000				0.0002000000	0.0002000000		0.0000890000			0.0002000000	0.0002000000		0.0002000000
Selenium	0.05	mg/L	<		0.0050000000				0.0010000000	0.0010000000		0.0010000000			0.0010000000	0.0010000000		0.0010000000
Thallium	0.002	mg/L	<		0.0002800000				0.0002800000	0.0010000000		0.0000280000			0.0002800000	0.0010000000		0.0010000000
Asbestos	7	MFL	<		0.1600000000				0.1600000000	0.1600000000		0.1600000000			0.1600000000	0.1600000000		0.1700000000
Cyanide	0.2	mg/L	<		0.0050000000				0.0100000000	0.0100000000		0.0100000000			0.0100000000	0.0100000000		0.0100000000
Fluoride	4	mg/L			0.4900000000				0.0380000000	0.1000000000		0.2600000000			0.0380000000	0.1000000000		0.3300000000
Nitrate (as N)	10	mg/L			0.1900000000				0.0130000000	0.1000000000		0.0130000000			0.0130000000	0.1000000000		0.1000000000
Nitrite (as N)	1	mg/L			0.0300000000				0.0330000000	0.1000000000		0.0330000000			0.0330000000	0.1000000000		0.1000000000
Nitrate-Nitrite (as N)		mg/L			0.190000				0.100000	0.100000								
<b>Organic Chemicals</b>																		
1,1,1-Trichloroethane	0.2	mg/L	<		0.0001000000				0.0001360000	0.0005000000		0.0000360000			0.0001360000	0.0005000000		0.0005000000
1,1,2-Trichloroethane	0.005	mg/L	<		0.0004200000				0.0004200000	0.0005000000		0.0000420000			0.0004200000	0.0005000000		0.0005000000
1,1-Dichloroethylene	0.007	mg/L	<		0.0006700000				0.0006700000	0.0005000000		0.0000670000			0.0006700000	0.0005000000		0.0005000000
1,2,4-Trichlorobenzene	0.07	mg/L	<		0.0007700000				0.0007700000	0.0005000000		0.0000770000			0.0007700000	0.0005000000		0.0005000000
1,2-Dibromo-3-chloropropane	0.0002	mg/L	<		0.0000310000				0.0000310000	0.0001000000		0.0000310000			0.0000310000	0.0001000000		0.0001000000
1,2-Dichlorobenzene	0.6	mg/L	<		0.0004900000				0.0004900000	0.0005000000		0.0000490000			0.0004900000	0.0005000000		0.0005000000
1,2-Dichloroethane	0.05	mg/L	<		0.0001000000				0.0001300000	0.0005000000		0.0001300000			0.0001300000	0.0005000000		0.0005000000
1,2-Dichloropropane	0.005	mg/L	<		0.0001600000				0.0001600000	0.0005000000		0.0001600000			0.0001600000	0.0005000000		0.0005000000
1,4-Dichlorobenzene	0.075	mg/L	<		0.0004600000				0.0004600000	0.0005000000		0.0000460000			0.0004600000	0.0005000000		0.0005000000
2,3,7,8-TCDD (dioxin)	0.00000003	mg/L	<		0.0000000050				0.0000000050	0.0000000050		0.0000000050			0.0000000050	0.0000000050		0.0000000050
2,4,5-TP (silvex)	0.05	mg/L	<		0.0001000000				0.0001000000	0.0002000000		0.0002000000			0.0002000000	0.0002000000		0.000200
2,4-Dichlorophenoxyacetic Acid	0.07	mg/L	<		0.0001000000				0.0001000000	0.0001000000		0.0001000000			0.0001000000	0.0001000000		0.000100
Aldicarb	0.002	mg/L	<		0.0004000000				0.0004000000	0.0004000000		0.0004000000			0.0004000000	0.0004000000		0.000400
Aldicarb sulfone	0.003	mg/L	<		0.0002000000				0.0002000000	0.0002000000		0.0002000000			0.0002000000	0.0002000000		0.000200
Atrazine	0.003	mg/L	<		0.0002000000				0.0002000000	0.0002000000		0.0002000000			0.0002000000	0.0002000000		0.000200
Benzene	0.005	mg/L	<		0.0004200000				0.0004200000	0.0005000000		0.0000420000			0.0004200000	0.0005000000		0.0005000000
Benzo(a)pyrene	0.0002	mg/L	<		0.0000200000				0.0000200000	0.0000200000		0.0000200000			0.0000200000	0.0000200000		0.000020
Carbofuran	0.04	mg/L	<		0.0020000000				0.0020000000	0.0020000000		0.0020000000			0.0020000000	0.0020000000		0.002000
Carbon Tetrachloride	0.005	mg/L	<		0.0000600000				0.0000600000	0.0005000000		0.0000600000			0.0000600000	0.0005000000		0.0005000000
Chlordane	0.002	mg/L	<		0.0001000000				0.0001000000	0.0001000000		0.0001000000			0.0001000000	0.0001000000		0.0001000000
Chlorobenzene	0.1	mg/L	<		0.0001000000				0.0001000000	0.0005000000		0.0001000000			0.0001000000	0.0005000000		0.0005000000
cis-1,2-Dichloroethylene	0.07	mg/L	<		0.0006300000				0.0006300000	0.0005000000		0.0006300000			0.0006300000	0.0005000000		0.0005000000
Dalapon	0.2	mg/L	<		0.0001000000				0.0001000000	0.0001000000		0.0001000000			0.0001000000	0.0001000000		0.001000
Di(2-ethylhexyl)adipate	0.4	mg/L	<		0													