

BDD Finished Drinking Water			January 7, 2020		January 21, 2020		July 30, 2020	
Sampled By:			NMED		BDD		NMED	
Parameter	MCL	Units	Result	MRL	Result	RL	Result	MRL
Primary Contaminants								
<i>Inorganic Chemicals</i>								
Antimony	0.006	mg/L	< 0.0010000	0.0010000				
Arsenic	0.01	mg/L	< 0.0010000	0.0010000				
Barium	2	mg/L	0.0360000	0.0020000				
Beryllium	0.004	mg/L	< 0.0010000	0.0010000				
Cadmium	0.005	mg/L	< 0.0005000	0.0005000				
Chromium	0.1	mg/L	< 0.0060000	0.0060000				
Mercury	0.002	mg/L	< 0.0002000	0.0002000				
Selenium	0.05	mg/L	< 0.0010000	0.0010000				
Thallium	0.002	mg/L	< 0.0005000	0.0005000				
Cyanide	0.2	mg/L	< 0.0100000	0.0100000				
Fluoride	4	mg/L	0.3700000	0.1000000				
Nitrate-Nitrite (as N)		mg/L	< 0.5000000	0.5000000				
<i>Organic Chemicals</i>								
1,1,1-Trichloroethane	0.2	mg/L	< 0.0005000	0.0005000				
1,1,2-Trichloroethane	0.005	mg/L	< 0.0005000	0.0005000				
1,1-Dichloroethylene	0.007	mg/L	< 0.0005000	0.0005000				
1,2,4-Trichlorobenzene	0.07	mg/L	< 0.0005000	0.0005000				
1,2-Dibromo-3-chloropropane	0.0002	mg/L	< 0.0000190	0.0000190			< 0.0000190	0.0000190
1,2-Dichlorobenzene	0.6	mg/L	< 0.0005000	0.0005000				
1,2-Dichloroethane	0.005	mg/L	< 0.0005000	0.0005000				
1,2-Dichloropropane	0.005	mg/L	< 0.0005000	0.0005000				
1,4-Dichlorobenzene	0.075	mg/L	< 0.0005000	0.0005000				
2,4,5-TP (Silvex)	0.05	mg/L	< 0.0002000	0.0002000			< 0.0002000	0.0002000
2,4-Dichlorophenoxyacetic Acid	0.07	mg/L	< 0.0001000	0.0001000			< 0.0001000	0.0001000
Alachlor	0.002	mg/L	< 0.0002000	0.0002000			< 0.0002000	0.0002000
Aldicarb	0.003	mg/L	< 0.0020000	0.0020000				
Atrazine	0.003	mg/L	< 0.0001000	0.0001000			< 0.0001000	0.0001000
Benzene	0.005	mg/L	< 0.0005000	0.0005000				
Benzo(a)pyrene	0.0002	mg/L	< 0.0000200	0.0000200			< 0.0000200	0.0000200
Carbofuran	0.04	mg/L	< 0.0009000	0.0009000			< 0.0009000	0.0009000

BDD Finished Drinking Water			January 7, 2020		January 21, 2020		July 30, 2020	
Sampled By:			NMED		BDD		NMED	
Parameter	MCL	Units	Result	MRL	Result	RL	Result	MRL
Carbon Tetrachloride	0.005	mg/L	< 0.0005000	0.0005000				
Chlordane	0.002	mg/L	< 0.0001000	0.0001000			< 0.0001000	0.0001000
Chlorobenzene	0.1	mg/L	< 0.0005000	0.0005000				
cis -1,2-Dichloroethylene	0.07	mg/L	< 0.0005000	0.0005000				
Dalapon	0.2	mg/L	< 0.0010000	0.0010000				
Di(2-ethylhexyl)adipate	0.4	mg/L	< 0.0002000	0.0002000			< 0.0002000	0.0002000
Di(2-ethylhexyl)phthalate	0.006	mg/L	< 0.0006000	0.0006000				
Dichloromethane	0.005	mg/L	< 0.0005000	0.0005000				
Dinoseb	0.007	mg/L	< 0.0002000	0.0002000			< 0.0002000	0.0002000
Diquat	0.02	mg/L	< 0.0004000	0.0004000				
Endothall	0.1	mg/L	< 0.0090000	0.0090000			< 0.0090000	0.0090000
Endrin	0.002	mg/L	< 0.0000100	0.0000100			< 0.0000100	0.0000100
Ethylbenzene	0.7	mg/L	< 0.0005000	0.0005000				
Ethylene Dibromide	0.00005	mg/L	< 0.0000093	0.0000093			< 0.0000093	0.0000093
Gamma-BHC (Lindane)	0.0002	mg/L	< 0.0000200	0.0000200			< 0.0000200	0.0000200
Glyphosate	0.7	mg/L	< 0.0050000	0.0050000			< 0.0050000	0.0050000
Heptachlor	0.0004	mg/L	< 0.0000400	0.0000400			< 0.0000400	0.0000400
Heptachlor Epoxide	0.0002	mg/L	< 0.0000200	0.0000200			< 0.0000200	0.0000200
Hexachlorobenzene	0.001	mg/L	< 0.0001000	0.0001000			< 0.0001000	0.0001000
Hexachlorocyclopentadiene	0.05	mg/L	< 0.0001000	0.0001000			< 0.0001000	0.0001000
Methoxychlor	0.04	mg/L	< 0.0001000	0.0001000			< 0.0001000	0.0001000
Oxamyl (Vydate)	0.2	mg/L	< 0.0020000	0.0020000				
PCBs	0.0005	mg/L	< 0.0001000	0.0001000			< 0.0001000	0.0001000
Pentachlorophenol	0.001	mg/L	< 0.0000400	0.0000400			< 0.0000400	0.0000400
Picloram	0.5	mg/L	< 0.0001000	0.0001000			< 0.0001000	0.0001000
Simazine	0.004	mg/L	< 0.0000700	0.0000700			< 0.0000700	0.0000700
Styrene	0.1	mg/L	< 0.0005000	0.0005000				
Tetrachloroethylene	0.005	mg/L	< 0.0005000	0.0005000				
Toluene	1	mg/L	< 0.0005000	0.0005000				
Toxaphene	0.003	mg/L	< 0.0010000	0.0010000			< 0.0010000	0.0010000
trans -1,2-Dichloroethylene	0.1	mg/L	< 0.0005000	0.0005000				
Trichloroethylene	0.005	mg/L	< 0.0005000	0.0005000				
Vinyl Chloride	0.002	mg/L	< 0.0005000	0.0005000				
Xylenes (Total)	10	mg/L	< 0.0005000	0.0005000				

BDD Finished Drinking Water			January 7, 2020		January 21, 2020		July 30, 2020	
Sampled By:			NMED		BDD		NMED	
Parameter	MCL	Units	Result	MRL	Result	RL	Result	MRL
<u>Radionuclides</u>								
Gross Alpha	15	pCi/L	1.2000000					
Gross Beta	(4 mrem/yr)	pCi/L	2.7000000					
Uranium	0.03	mg/L	0.0020000					
Radium-226/228	5	pCi/L	0.2500000					
Secondary Contaminants								
Zinc	5	mg/L	0.0530000	0.0100000				
Other Parameters								
Calcium		mg/L			34.00	1.0		
Magnesium		mg/L			6.30	1.0		
Sodium		mg/L	24.0000000	1.0000000				
Hardness (as CaCO ₃)		mg/L			110.00	6.6		
Strontium-90		pCi/L					< 0.8600000	0.8600000
Tritium		pCi/L					< 230.0000000	230.0000000

MCL = Maximum Contamination Level

MRL = Minimum Reporting Limit

RL - Reporting Limit