

BDD Finished Drinking Water			November 29, 2021	
Sampled By:			NMED	
Parameter	MCL	Units	Result	MRL
Primary Contaminants				
<i>Inorganic Chemicals</i>				
Antimony	0.006	mg/L	< 0.0010	0.0010
Arsenic	0.01	mg/L	< 0.0010	0.0010
Barium	2	mg/L	0.0380	0.0020
Beryllium	0.004	mg/L	< 0.0010	0.0010
Cadmium	0.005	mg/L	< 0.0010	0.0010
Chromium	0.1	mg/L	< 0.0010	0.0010
Selenium	0.05	mg/L	< 0.0050	0.0050
Thallium	0.002	mg/L	< 0.0010	0.0010
Cyanide	0.2	mg/L	< 0.0050	0.0050
Fluoride	4	mg/L	0.4700	0.1000
Nitrate-Nitrite (as N)		mg/L	0.0700	0.0500
<i>Organic Chemicals</i>				
1,1,1-Trichloroethane	0.2	mg/L	< 0.0005	0.0005
1,1,2-Trichloroethane	0.005	mg/L	< 0.0005	0.0005
1,1-Dichloroethylene	0.007	mg/L	< 0.0005	0.0005
1,2,4-Trichlorobenzene	0.07	mg/L	< 0.0005	0.0005
1,2-Dichlorobenzene	0.6	mg/L	< 0.0005	0.0005
1,2-Dichloroethane	0.005	mg/L	< 0.0005	0.0005
1,2-Dichloropropane	0.005	mg/L	< 0.0005	0.0005
1,4-Dichlorobenzene	0.075	mg/L	< 0.0005	0.0005
Benzene	0.005	mg/L	< 0.0005	0.0005
Carbon Tetrachloride	0.005	mg/L	< 0.0005	0.0005
Chlorobenzene	0.1	mg/L	< 0.0005	0.0005
<i>cis</i> -1,2-Dichloroethylene	0.07	mg/L	< 0.0005	0.0005
Dichloromethane	0.005	mg/L	< 0.0005	0.0005
Ethylbenzene	0.7	mg/L	< 0.0005	0.0005
Styrene	0.1	mg/L	< 0.0005	0.0005
Tetrachloroethylene	0.005	mg/L	< 0.0005	0.0005
Toluene	1	mg/L	< 0.0005	0.0005
<i>trans</i> -1,2-Dichloroethylene	0.1	mg/L	< 0.0005	0.0005
Trichloroethylene	0.005	mg/L	< 0.0005	0.0005
Vinyl Chloride	0.002	mg/L	< 0.0005	0.0005
Xylenes (Total)	10	mg/L	< 0.0005	0.0005
Other Parameters				
Nickel		mg/L	< 0.0100	0.0100
Strontium-90		pCi/L	< 0.8700	0.8700
Tritium		pCi/L	< 240.0000	240.0000

MCL = Maximum Contamination Level

MRL = Minimum Reporting Limit