

BDD Finished Drinking Water			October 18, 2022	
Sampled By:			NMED	
Parameter	MCL	Units	Result	MRL
<b>Primary Contaminants</b>				
<b><i>Inorganic Chemicals</i></b>				
Antimony	0.006	mg/L	< 0.0010000	0.0010000
Arsenic	0.01	mg/L	< 0.0010000	0.0010000
Barium	2	mg/L	0.0480000	0.0030000
Beryllium	0.004	mg/L	< 0.0010000	0.0010000
Cadmium	0.005	mg/L	< 0.0005000	0.0005000
Chromium	0.1	mg/L	< 0.0060000	0.0060000
Mercury	0.002	mg/L	< 0.0002000	0.0002000
Selenium	0.05	mg/L	0.0012000	0.0010000
Thallium	0.002	mg/L	< 0.0002500	0.0002500
Cyanide	0.2	mg/L	< 0.0100000	0.0100000
Fluoride	4	mg/L	0.3200000	0.1000000
Nitrate-Nitrite (as N)		mg/L	< 0.0005000	0.0005000
<b><i>Organic Chemicals</i></b>				
1,1,1-Trichloroethane	0.2	mg/L	< 0.0005000	0.0005000
1,1,2-Trichloroethane	0.005	mg/L	< 0.0005000	0.0005000
1,1-Dichloroethylene	0.007	mg/L	< 0.0005000	0.0005000
1,2,4-Trichlorobenzene	0.07	mg/L	< 0.0005000	0.0005000
1,2-Dichlorobenzene	0.6	mg/L	< 0.0005000	0.0005000
1,2-Dichloroethane	0.005	mg/L	< 0.0005000	0.0005000
1,2-Dichloropropane	0.005	mg/L	< 0.0005000	0.0005000
1,4-Dichlorobenzene	0.075	mg/L	< 0.0005000	0.0005000
Benzene	0.005	mg/L	< 0.0005000	0.0005000
Carbon Tetrachloride	0.005	mg/L	< 0.0005000	0.0005000
Chlorobenzene	0.1	mg/L	< 0.0005000	0.0005000
<i>cis</i> -1,2-Dichloroethylene	0.07	mg/L	< 0.0005000	0.0005000
Dichloromethane	0.005	mg/L	< 0.0005000	0.0005000
Ethylbenzene	0.7	mg/L	< 0.0005000	0.0005000
Styrene	0.1	mg/L	< 0.0005000	0.0005000
Tetrachloroethylene	0.005	mg/L	< 0.0005000	0.0005000
Toluene	1	mg/L	< 0.0005000	0.0005000
<i>trans</i> -1,2-Dichloroethylene	0.1	mg/L	< 0.0005000	0.0005000
Trichloroethylene	0.005	mg/L	< 0.0005000	0.0005000
Vinyl Chloride	0.002	mg/L	< 0.0005000	0.0005000
Xylenes (Total)	10	mg/L	< 0.0005000	0.0005000
<b>Secondary Contaminants</b>				
Zinc	5	mg/L	0.0380000	0.0100000
<b>Other Parameters</b>				
Nickel		mg/L	< 0.0100000	0.0100000
Sodium		mg/L	23.0000000	1.0000000
Strontium-90		pCi/L	< 0.3400000	0.3400000
Tritium		pCi/L	< 270.0000000	270.0000000

MCL = Maximum Contamination Level

MRL = Minimum Reporting Limit